

CHATHAM AREA TRANSIT AUTHORITY IFB 2012-03, ADDENDUM NO. 4

DATE: January 27, 2012
ORIGINAL IFB NUMBER: 2012-03
PROJECT: CHATHAM AREA TRANSIT AUTHORITY DOWNTOWN INTERMODAL
TRANSIT CENTER

This Addendum forms a part of the Invitation for Bids 2012-03 dated January 3, 2012.

I. PROJECT MANUAL:

A. Section 084513, Structured-Polycarbonate-Panel Assemblies:

1. Paragraph 2.1A, add the following name to the list of manufacturers:
 4. Architectural Daylighting, LLC.
2. Paragraph 2.2, add:
 - G. Panel assembly shall withstand impact loading by blunt object of 500 ft. lbs. per ASTM E695-03."
3. Paragraph 2.3A, add:
 2. Aluminum purlins spaced 3'-0" O.C. max. unless otherwise noted in the drawings.
4. Delete Paragraph 2.7 in its entirety.

B. Below is a list manufacturers which have requested, but have not been granted, prior approval:

1. Section 034500 – Precast Architectural Concrete:
 - a. Architectural Concrete Casting, Inc.
2. Section 074243 – Solid Phenolic Wall Panels:
 - a. TRESPA "Meteon."
3. Section 075419 Polyvinyl-Chloride (PVC) Roofing:
 - a. Johns-Manville.
4. Section 102220 – Demountable Partitions:
 - a. Haworth, Inc. "Enclose."
 - b. INSCAPE Architectural Interiors "Reform Walls."
 - c. Modulo Pareti, "Modulo Interior Glass Wall Systems."
 - d. Steelcase "Privacy Wall."

END OF ADDENDUM NO. 4