

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO Bid No. 12-0091-7

FOR: Replacement Water Tank at Glen of Robin Hood Water System

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. **CHANGE:** Section 4.3.2, to read "96"OD x 312" Seam/Seam Horizontal Tank on Two (2) Saddles".
2. **ADDITION:** Section 4.3.9, will include in addition to the items listed, one (1) 1" air relief valve with a 1" 3000# coupling.
3. **CLARIFICATION:** Section 4.3.10, Discharge valve on the Lester Avenue side of the water tank must be replaced. The valve that needs to be replaced is 10".
4. **ADDITION:** Section 4.5, COUNTY RESPONSIBILITIES, Chatham County will notify residents in the immediate area that the water tank is being replaced. However, it is the responsibility of the Contractor to give Chatham County a three (3) day notice of any temporary shutdown of the Glen of Robin Hood well.
5. The contractor, or any subcontractor, submitting a bid for utility contracting, as defined in O.C.G.A. Section 43-14-2 to a utility system as defined in said section, shall conform to O.C.G.A. Section 43-14-8.2 et seq. with reference to Utility Contractor's Licenses. Utility contracting means a proposal to perform utility work to a utility system as defined in O.C.G.A. Section 43-14-2(17).

THE BID OPENING SHALL REMAIN 2PM SEPTEMBER 13, 2012.

THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

09-11-12
DATE


MARGARET H. JOYNER
PURCHASING AGENT
CHATHAM COUNTY