

CHATHM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO BID NO. 13-0003-6

**FOR: ULTRAVIOLET SANITATION SYSTEM FOR CHATHAM COUNTY
AQUATIC CENTER**

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLAIRIFICATIONS, AND/OR CHANGES:

NOTE: The following questions were asked following the pre-bid conference held on January 30, 2013

1. My understanding is that the replumbing can NOT block the filter access (manway holes). Is this correct? **We do not want the new plumbing to block access to our filters.**
2. Aquatic Center staff said during the pre-bid conference that the "UV must be installed so only filtered water passes through the unit". Does this include during a filter backwash cycle? **Based on our current UV system for the recreation pool we have the ability to bypass the UV unit while we backwash.**
3. In the specs page 14, 3rd paragraph it states "Included in the work should be an isolation valve for maintenance work". I can only assume this means a "bypass" so the pool can continue to circulate during equipment service times. Can you confirm this? **Yes, we want a bypass installed so that during maintenance of the UV unit, the pool still circulates.**

NOTE: BID OPENING DATE AND TIME WILL REMAIN THE SAME - 2:00 P.M. FEBRUARY 7, 2013

THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

FEBRUARY 1, 2013
DATE


MARGARET H JOYNER
PURCHASING AGENT