

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 1 TO Bid No. 13-0024-4

FOR: Kings Ferry Park Irrigation and Landscaping Improvement

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:


1. The Perennial and Grass plantings listed under the "*Pocket Wetland Planting Schedule*" on sheet P.02 are to be omitted from this project scope. The trees are to remain.
2. All plant material shall be warrantied for a period of two (2) years.
3. The irrigations system shall be warrantied for a period of one (1) year.
4. Bidders shall include providing the County a "walk through" of the project at completion to provide instruction on how to operate and maintain the irrigation system along with maintenance and care for the plant material.
5. The timbers for the headwall is to be 6" x 6" x 8'.
6. The top of the headwall shall be flush with the top of sidewalk.
7. The contract is responsible to provide earth backfill, if required. The headwall shall be directly adjacent to and flush with the top of sidewalk.
8. The filter strips are existing and not part of this contract.
9. According to the Chatham County Public Works and Park Services Department, the well at Kings Ferry Park will push 90-100 psi.

NOTE: An "On-Site" visit to the park has been scheduled for the purpose to examine the well. The visit is scheduled for 2:00pm - 3:00pm, Wednesday, April 17, 2013.

THE BID OPENING HAS BEEN EXTENDED TO: 2PM, APRIL 24, 2013.

**THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND
MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.**

4-12-13
DATE



ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST
CHATHAM COUNTY