

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO BID 13-0060-7

FOR: Annual Contract for Maintenance and Repairs of Sluice Gates located on GPA

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. **Question:** What is the current condition/issues of the sluice gates?

Response: The current condition/issues are as follows:

- a. Drive nuts are stripped - need to replace drive nuts bearings and thrust washers. (Working on getting new nuts re-machined.)
- b. Upstream transducer is not functioning at all. (Correct input voltage to power the transducer controller, correct excitation voltage to transducer)
- c. Stem covers need to be replaced. (5" Sch40 PVC 11' long with capped on one end 5 in threaded fitting on the other)
- d. Gate percent open/close readings need to be recalibrated.
- e. Backup battery for computer controller needs to be replaced.
- f. Computer controller and logic board need testing.

**BID DUE DATE REMAINS 2:00PM
AUGUST 27, 2013.**

*******THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY
CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.*******

08/22/13

DATE



MARGARET H. JOYNER

PURCHASING AGENT

CHATHAM COUNTY