

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO BID NO. 14-0009-4

FOR: LIBERTY CITY COMMUNITY CENTER ADDITION

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:


Substitution Submittals :

1. Specification Section 07 41 00 Standing Seam Metal Roofing System:
ENGLERT SERIES 2500 IS ACCEPTABLE AS A SUBSTITUTION.
2. Specification Section 07 41 00 Standing Seam Metal Roofing System:
DREXELL DMC 2005 IS ACCEPTABLE AS A SUBSTITUTION.
3. Specification Section 13 34 19 Metal Building Systems:
AIM IS ACCEPTABLE AS A SUBSTITUTION.

NOTE: Signed approval forms for each substitution request are attached to this addendum(3 pages)

BID OPENING REMAINS: 2PM, FEBRUARY 27, 2014

2-13-14
DATE


ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST
CHATHAM COUNTY



Pre-Bid Substitution Request

Request Date: 2/3/14

Project Name: Liberty City Community Center (Addition)

Location: Savannah, GA

Chatham County ATTN: Robert Marshall

Architect

Street

City, State

rmarshall@chathamcounty.org

Phone

Fax

Email

We respectfully request a substitute product for your consideration on the above project:

<u>07 41 00</u>	<u>2.2</u>	<u>MBCI Super Lok</u>	<u>Englert Series 2500</u>
			<u>Metalman HT Underlayment</u>

Section	Paragraph	Specified Product	Proposed Product
---------	-----------	-------------------	------------------

The following changes will occur by accepting the proposed product:

Dimensional Changes in Drawing: _____

Affects on Other Installers: _____

Differences Between Proposed / Accepted: _____

Differences in Warranties: 35 Year Paint Finish Warranty

Submitted By:

Steve Gaffney

Product Solutions Consultant

Name

Title

Cell: 404-780-2528

Location

s.gaffney@englertinc.com

Phone / Fax

Email

Architect's Comments:

ACCEPTED

ACCEPTED AS NOTED

NOT ACCEPTED AS NOTED

Completed By

Thomas [Signature]

02/13/2014



SUBSTITUTION REQUEST



Substitution Request Number: _____

Project: LIBERTY CITY COMMUNITY CENTER

From: GEOFF ELLIOTT

To: TOM OLSON

Date: _____

Firm: KERN & COLEMAN

A/E Project # _____

Re: _____

Contract For: _____

Specification Title: STANDING SEAM METAL ROOF SYSTEM Description: _____

Section: 074100 Page: 1 Article/Paragraph: 2.1

Proposed Substitution: DREXEL DMC 200S 2 INCH STANDING SEAM PANEL

Manufacturer: Drexel Metals Inc.

Address: 1234 Gardiner Lane

Trade Name: _____

City, St, Zip: Louisville, KY 40213

Attached data includes product description, specifications, drawings, photographs, and performance and test data adequate for evaluation of the request; applicable portions of the data are clearly identified.

Attached data also includes a description of changes to the Contract Documents that the proposed substitution will require for its proper installation.

The Undersigned certifies:

- Proposed substitution has been fully investigated and determined to be equal or superior in all respects to specified product.
- Same warranty will be furnished for proposed substitution as for specified product.
- Same maintenance service and source of replacement parts, as applicable, is available.
- Proposed substitution will have no adverse effect on other trades and will not affect or delay progress schedule.
- Proposed substitution does not affect dimensions and functional clearances.
- Payment will be made for changes to building design, including A/E design, detailing, and construction costs caused by the substitution.

Submitted by: Geoff Elliott Signed: _____

Firm: Drexel Metals Inc.

Address: 1234 Gardiner Lane

City, St, Zip: Louisville, KY 40213

Telephone: 404 394-5397

Fax: 877.321.9638

Email: gelliott@drexmet.com

A/E's REVIEW AND ACTION

- Substitution approved - Make submittals in accordance with Specification Section 01 25 00 Substitution Procedures.
- Substitution approved as noted - Make submittals in accordance with Specification Section 01 25 00 Substitution Procedures.
- Substitution rejected - Use specified materials.
- Substitution Request received too late - Use specified materials.

Signed by: Thomas Olson

Date: 02/13/2014

Supporting Data Attached: Drawings Product Data Samples Tests Reports Photos



SUBSTITUTION REQUEST (During the Bidding Phase)

Project: Chatham County Liberty City Community Center

Substitution Request Number: _____

Savannah, GA

From: Greg Clement (AIM Inc. representative) 770-605-7937

To: Bob Marshall

Date: 2/7/14

Chatham County Purchasing

A/E Project Number: _____

Re: Pre bid approval PEMB Section 13

Contract For: Chatham Liberty City Community Center

Specification Title: Metal Building System

Description: Metal Building

Section: 13 3419 Page: all

Article/Paragraph: all

Proposed Substitution: AIM Pre Engineered Metal Building System

Manufacturer: AIM, Inc. Address: Columbus, Ga

Phone: 770-605-7937

Trade Name: _____

Model No.: _____

Attached data includes product description, specifications, drawings, photographs, and performance and test data adequate for evaluation of the request; applicable portions of the data are clearly identified.

Attached data also includes a description of changes to the Contract Documents that the proposed substitution will require for its proper installation.

The Undersigned certifies:

- Proposed substitution has been fully investigated and determined to be equal or superior in all respects to specified product.
- Same warranty will be furnished for proposed substitution as for specified product.
- Same maintenance service and source of replacement parts, as applicable, is available.
- Proposed substitution will have no adverse effect on other trades and will not affect or delay progress schedule.
- Proposed substitution does not affect dimensions and functional clearances.
- Payment will be made for changes to building design, including A/E design, detailing, and construction costs caused by the substitution.

Submitted by: Greg Clement

Signed by: _____

Firm: AIM Metals/Buildings

Address: Columbus, Ga

Telephone: 770-605-7937

A/E REVIEW AND ACTION

- Substitution approved - Make submittals in accordance with Specification Section 01330.
- Substitution approved as noted - Make submittals in accordance with Specification Section 01330.
- Substitution rejected - Use specified materials.
- Substitution Request received too late - Use specified materials.

Signed by: _____

Date: _____

02/13/2014

Supporting Data Attached: Drawings Product Data Samples Tests Reports _____