

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO BID # 15-0099-7

FOR: Upgrade of the Sanitary Sewer Lift Station at Lake Mayer Community Park

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:


1. **Question: Ref. Section 4.2.9** – Requires washing the wet well. Is the Contractor to epoxy coat the wet well? Epoxy coat the new pipe?
Response: The Contractor is to wash out the wet well, no epoxy coating.
2. **Question: Ref. Section 4.2.7** - Indicates new valve box with new check valves. Is the Contractor to install new plug valves?
Response: No, new plug valves.
3. **Question: Ref. Section 4.2.8** – Indicates to replace piping and tie into existing. Please define the extent of the new pipe limits. Is all the piping to be replaced from the pump bases to the other side of the new valve box?
Response: All piping is to be replaced, starting at the pump bases to the other side of the new valve box.
4. **Question:** Is a drain line to be installed from the new valve vault into the lift station? If yes, what size and what is required on the end?
Response: Drain line is not to be installed.
5. **Change: Section 4.2.7** shall read “Contractor shall install new cement check valve box and new check valves with an aluminum lid”.
6. **Change: Section 4.2.8** shall read “Contractor shall install two (2) new 3 inch steel discharge pipes and tie into existing lines. New pipe shall be ductile and does not require epoxy lining”.
7. **Change: Section 4.2.1** shall read “Contractor will remove all blocks except the bottom two (2) rows of the cinder block structure that is surrounding the old wet well. Contractor shall block all holes under the existing cement pad. Sloping should match the surrounding area.
8. **Change: Section 4.2.2** shall read “Contractor will clean the former wet well and place a metal frame approximately 4 foot 6 inches square with two handles and no manhole cover. Contractor will be responsible for exact measurement”.

**THE PROPOSAL DUE DATE IS 2:00PM,
OCTOBER 15, 2015.**

PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

October 9, 2015

DATE



MARGARET H. JOYNER
PURCHASING DIRECTOR
CHATHAM COUNTY