

CHATHAM COUNTY PURCHASING DEPARTMENT
ADDENDUM NO. 1 TO BID # 16-0064-7

FOR: Detention Center Boiler Replacement

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. **Question:** Are stop valves required in the gas line to each boiler?
Response: Yes, see specification 22.1123 for gas piping and valves.

2. **Question:** Can gas be shut off to install valves?
Response: Yes, for short periods, all shut downs must be coordinated with the County Project Manager.


3. **Question:** Will emergency boiler shut down be required for the boilers?
Response: Emergency shut off button for all boilers is to be located at each exit door from the space. This includes the roll-up door, hall door and electrical room door.

**THE BID OPENING REMAINS 2:00PM,
SEPTEMBER 6, 2016.**

PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

August 22, 2016

DATE



 MARGARET H. JOYNER
PURCHASING DIRECTOR
CHATHAM COUNTY