

CHATHAM COUNTY PURCHASING DEPARTMENT
ADDENDUM NO. 1 TO BID # 17-0042-7

FOR: UPGRADE OF ELEVATOR SYSTEMS AT THE CHATHAM COUNTY PARKING GARAGE

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:


1. **CHANGE:** Section 142100 "Electric Traction Elevators" is amended as follows: At Section 2.1 add Subsection C which reads as follows: "C. Elevator Component manufacturers: Approved elevator component manufacturers include: Smartwise, GAL, Draka and Innovation."
2. **CHANGE:** Ref. Plan Sheet A100 – Delete Note 8 and replace with note that reads as follows: "Note 8: Provide 18 GA galvanized sheet metal enclosure between room and shaft to prevent fall hazard. Secure sheet metal to 2" x 2" x 1/8" perimeter steel angle, prime painted, secured to floor, walls and ceiling. Create custom perimeter 2" x 2" perimeter frame surrounding elevator hoist machine within 6" of machine and then apply additional sheet metal from this frame to within 1" of elevator hoist machine. This additional sheet metal enclosure to be secured with screws which is removable to allow for equipment maintenance as needed. Prime paint all cut edges of steel and provide shop drawings for approval".
3. **CHANGE:** Commencement and Completion shall now read, "WORK SHALL BEGIN WITHIN TEN (10) DAYS AFTER RECEIPT OF NOTICE TO PROCEED. ALL WORK SHALL BE COMPLETED WITHIN 120 CALENDAR DAYS AFTER THE TEN DAY PERIOD.

THE BID OPENING REMAINS 2:00PM, JUNE 6, 2017.

PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

June 2, 2017

DATE



MARGARET H. JOYNER
PURCHASING DIRECTOR
CHATHAM COUNTY