

CHATHAM COUNTY PURCHASING DEPARTMENT
ADDENDUM NO. 1 TO BID # 17-0110-7
FOR: RALPH MARK GILBERT CIVIL RIGHTS MUSEUM REROOF PROJECT

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR
CHANGES:


1. **CHANGE:** The scope of work has been increased to include an interior fixed ladder.
See Sheet A3.2.
2. **CHANGE:** Various minor clarifications to the drawings.
3. **Question:** Ref. Section 075419, SubSection 1.5-2c – Is it possible to use an OSHA approved fall system without having to erect the scaffolding?
Response: No, due to safety concerns, the County requires scaffolding to provide protection for the workers on top of the roof and for the pedestrians on the ground from any debris/materials/tools etc that may slide off the roof during construction.

**THE BID OPENING REMAINS 2:00 P.M.,
DECEMBER 5, 2017.**

BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

November 29, 2017

DATE


MARGARET H. JOYNER
PURCHASING DIRECTOR
CHATHAM COUNTY