

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO RFP NO. 17-0004-6

FOR: ANNUAL CONTRACT FOR PREVENTIVE MAINTENANCE AND SERVICES ON  
FOUR (4) UNINTERRUPTIBLE POWER SUPPLY UNITS


PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. **CLARIFICATION: Section 5.5.1 Battery Replacement.** Below is a list of battery information pertaining to each UPS unit.

UPS Make/Model	UPS Serial Number	Battery Type	Battery Quantity
Powerware 9315 100kVA	EP026ZBA02	CSB HRL12390WFR	1 string 40 batteries per string
Eaton Best Power Unity 1 30kVA (UT330)	LD 0202	CSB GP12260	2 strings 18 batteries per string
Powerware 9170 9kVA	BE141T0005	CSB GP1272F2FR	3 strings 10 batteries per string
Eaton Best Power Unity 1 30kVA (UT330)	LD 0435	CSB UPS12- 300MR	1 string 18 batteries per string

PLEASE NOTE: THE DUE DATE AND TIME WILL REMAIN  
THE SAME AT 5:00 PM FEBRUARY 7, 2017

January 19, 2017  
DATE

  
MARGARET H. JOYNER,  
PURCHASING DIRECTOR  
CHATHAM COUNTY GOVERNMENT