

CHATHAM COUNTY PURCHASING DEPARTMENT
ADDENDUM NO. 1 TO RFP #18-0047-7

FOR: Design and Engineering Services for Replacement of 16" Force Main on Sallie Mood Drive/Agonic Road

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:


1. **Question:** Casey Canal crossing will either be as it currently is or a bore under the canal - engineer to decide?
Response: Due to Casey Canal being in City of Savannah right-of-way, the Consultant will work with City Engineers to determine the best course to take in regards to boring under the canal or to connect as it stands now.
2. **Question:** Subsurface Utility (S.U.E.) will be needed? How much or how many cross sections?
Response: Yes, S.U.E. Level A every 200' to 400' based on the nearest conflicts (i.e., driveways, intersections, existing utilities, etc.).
3. **Question:** How will the utilities be located? By Radar, by potholing, and/or by design locate?
Response: Consultant will use the potholing method.
4. **Question:** Replace or slip line the existing FM?
Response: Consultant should recommend method by evaluating the capital and maintenance cost of the replaced force main.
5. **Question:** Proposed FM material (if replaced) - engineer will decide?:
Response: Consultant should recommend material of force main.
6. **Question:** Permitting with City's SPR?
Response: Consultant will be responsible for all City permitting.
7. **Question:** Permitting with NRCS for the erosion and pollution control plans?
Response: NRCS permit may be needed for Phase 1 but it will not be necessary for Phase 2.
8. **Question:** How much Geotechnical will be needed (Section 5.2.2.b)?
Response: Geotechnical bores every 500' should be adequate.
9. **Question:** Will an environmental site assessment be needed (Section 5.2.3.c)?
Response: No, an environmental site assessment will not be required.

**THE PROPOSAL DUE DATE HAS BEEN
EXTENDED TO 5:00 PM, JUNE 5, 2018.**

PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

May 23, 2018

DATE


MARGARET H. OYNER:
PURCHASING DIRECTOR
CHATHAM COUNTY