

CHATHAM COUNTY PURCHASING DEPARTMENT
ADDENDUM NO. 2 TO BID #18-0061-7

FOR: Sheftall Bluff Lift Station Upgrade

=====

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. **Question:** Mention was made during the pre-bid of raising the station lids. We only find reference in the plans to R/R both lids ? Is it to be raised ?
Response: The County is not requiring raising the top. It is required that the whole top cement and metal be removed and replaced.


**THE BID OPENING REMAINS 2:00 P.M., JULY
10, 2018.**

=====

BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

=====

July 3, 2018
DATE



MARGARET M. JOYNER:
PURCHASING DIRECTOR
CHATHAM COUNTY