

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 2 TO 19-0058-4

FOR: RENOVATIONS TO 41 PARK OF COMMERCE WAY, SUITES 304-306

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

NOTE: *Additional Questions Received* :

1. Q) Will "MC" cable be allowed for interior wiring in the walls and ceilings?

A) Yes.

2. Q) Who furnishes and installs the smoke and duct detectors?

A) See M1.0-Airside-Note 2

3. Q) Plans call for metal wall plates, should these be stainless steel or what type of finish?

A) Plates can be nylon-ivory

4. Q) What do we do with equipment that is to be removed?

A) Unused equipment shall be disposed of by contractor.

5. Q) Name plates are for panels and disconnect switches, any other name plates to be provided?

A) No other name plates are to be provided.

6. Q) What is the height to the underside of the roof deck within the space?

A) Approximately 18' at ridge.

7. Q) How is the ladder shown on sheet A-500 to be finished? Is it to receive paint, or powder coat?

A) Aluminum-mil finish.


NOTE: BID OPENING REMAINS:

2PM, TUESDAY, JUNE 25, 2019

THE PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

6/18/19

DATE



ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST
CHATHAM COUNTY