

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 1 TO 20-0022-4

FOR: CHATHAM COUNTY ICS OFFICE RENOVATION

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

NOTE: See attached sheet (1 page) for responses to questions received.

**BID OPENING REMAINS:
2PM, THURSDAY, MARCH 26, 2020**

THE PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

3/20/20
DATE



ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST
CHATHAM COUNTY

ADDENDUM No. 01

DATE: March 19, 2020

PROJECT: The Commissioners of Chatham County Georgia
Bid No. 20-0022-04
Chatham County ICS Office Renovation
Savannah, Georgia

BY: Cogdell & Mendrala Architects, PC (Architect)
517 East Congress Street
Savannah, GA 31401

This Addendum forms a part of the Contract Documents and modifies the original Drawings and Project Manual dated January 2020 and identified as (Construction Documents).

I. GENERAL INFORMATION:

A. Not applicable for Addendum No. 01.

II. SUBSTITUTION REQUESTS:

A. Not applicable for Addendum No. 01.

III. RFI RESPONSE:

- A. Is this work to take place after hours, or can it be performed Monday – Friday, 8:00AM – 5:00PM
1. Response: All work can be done during regular business hours.
- B. What is the size of the mechanical unit to be relocated?
1. Response: The existing mechanical unit to be relocated is a 24 MBH ducted VRF air handler by Mitsubishi.
- C. For the mechanical unit, is this unit a chiller water/hot water unit, or is it a DX refrigerant type unit?
1. Response: The existing unit is VRF (DX refrigerant type) by Mitsubishi.

IV. PROJECT MANUAL:

A. Not applicable for Addendum No. 01.

V. Drawings:

A. Not applicable for Addendum No. 01.

END OF ADDENDUM No. 01