

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 2 TO 20-0023-4

**FOR: CHATHAM PARKWAY OUTFALL DRAINAGE AND ACCESS  
IMPROVEMENTS**

---

**PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR  
CHANGES:**

**NOTE: SEE ATTACHED SHEET FOR RESPONSES TO QUESTIONS RECEIVED:  
( 1 page )**

---

**BID OPENING REMAINS: 2PM, TUESDAY, APRIL 7, 2020**

---

NOTE: DUE TO THE CURRENT *COVID-19* SITUATION, WE CAN NOT ALLOW ATTENDEES AT THE BID OPENING READING. IF YOU HAND CARRY YOUR BIDS, YOU MUST LEAVE THEM WITH A STAFF MEMBER AT THE FRONT DOOR OF OUR OFFICE AT 1117 EISENHOWER DRIVE, SUITE C, SAVANNAH. IF YOU SHIP THEM VIA FedEx OR UPS, WE RECOMMEND YOU SHIP A DAY OR TWO IN ADVANCE TO MAKE SURE THEY MEET THE 2:00PM DEADLINE. YOU CAN, HOWEVER, CALL IN AT 2:05PM TO HEAR THE BIDS READ ALOUD. TO CALL IN FOR THE BID OPENING, **call 1-888-585-9008 Conference Room access code 743-636-882**. AS ALWAYS, AFTER THE READING, THE BID TOTALS WILL BE UPLOADED ON OUR WEBSITE. WE APOLOGIZE FOR THE INCONVENIENCE.

**THE PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES  
AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.**

1/27/20

DATE



ROBERT E. MARSHALL

SENIOR PROCUREMENT SPECIALIST  
CHATHAM COUNTY

**Question Received for Addendum 2 of Bid No. 20-0023-4:**

**1. Q) Are Veteran owned business's included in the M/WBE participation goals?**

**A) No.**

**2. Q) Who is responsible for the staking /layout ?**

**A) *The County will have a surveyor establish horizontal and vertical control points on site prior to construction. The contractor will be responsible performing the remaining site layout/ staking work using these points.***

**3. Q) Are the permits in place and paid for by the County or does the Contractor have to apply and pay for them?**

**A) *All required permits are in place. The contractor will not need to obtain any permits.***

**4. Q) Is there a Payment and Performance bonds required for this project.**

**A) *Yes, as stated in the ITB.***

**5. Q) Item D (Grading) of the Part 10 – Measurement & Payment section says that “The item shall include excavation or filling not associated with conduit installation or drainage channel modifications”. What filling is referred to here and will this require some import on suitable materials not included in the item F (Foreign Borrow)?**

**A) *Since all the work that is in the project is associated with conduit installation and channel modifications, there is no known additional filling or excavation. However, the contractor in implementing his work plan may find that he needs to do some filling or excavation, or both, to complete the work. For example, in order to install the box culvert, it may be necessary to place temporary earth dams upstream and downstream in order to be able to keep the work area dry. The filling required to install the dams and the excavation required to remove them would be included in grading and not be paid separately.***