

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 6 TO 20-0027-5

**FOR: COOLING TOWERS REPLACEMENT AT CHATHAM COUNTY DETENTION CENTER**

---

**PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:**

**Question received:**

**1. Q) The revised bid form states the base bid includes replacement of the pumps, the bid option states replacing the pumps with VFD capable motors and VFD's and controls. Should replacement of the existing pumps with equal pumps be included in the base bid?**

***A) The bid does not state replacement of pumps is included in the Cooling Tower Replacement. The pump replacement with VFD and Controls is the add-on alternate and is bid separate from the Cooling Tower Replacement.***

**NOTE : THIS IS THE FINAL ADDENDUM FOR THIS BID.**

---

**BID OPENING REMAINS: 2:00 PM, THURSDAY, AUGUST 13, 2020.**

---

**THE PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.**

8/6/20  
DATE



ROBERT E. MARSHALL  
SENIOR PROCUREMENT SPECIALIST  
CHATHAM COUNTY