

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 1 TO 10-11-4-4

**FOR: Wilmington Island Road/N. Cromwell Road Intersection
Improvements & McCorkle Bike Trail Extension**

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR
CHANGES:

Wilmington Island Road / N. Cromwell Road Intersection Improvements:

* Contractor must use Filtrex, haybales or similar “non-trenchless” sediment barriers to ensure the critical root zones of the street trees are not impacted.


McCorkle Bike Trail Extension:

* Asphalt section for the bike path shall be 1.5" of 9.5mm Superpave (not 1.5 of 12.5mm Superpave.)

THE BID OPENING REMAINS: 2PM, JUNE 29, 2010

THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND
MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

6-18-10
DATE


ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST
CHATHAM COUNTY