

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO 11-0002-4

FOR: PAVING STONE STREET


PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

- 1. No polymer modified asphalt will be used on the job.**
- 2. 19 mm Superpave is not required for driveways. Asphalt driveway sections shall consist of 6" GAB and 165 lb/sy of 12.5 mm Superpave.**
- 3. Recycled asphalt is not to be used on the project. Only regular Superpave asphalt concrete mixtures are to be used in accordance with Section 828.2.03 of GDOT standards and specifications.**

THE BID OPENING REMAINS : 2PM, THURSDAY, AUGUST 18, 2011.

THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

8-15-11
DATE



ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST
CHATHAM COUNTY