

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO 11-1-17-7

**FOR: PROVIDE AND INSTALL OCCUPANCY LIGHT SENSOR SYS. @ THE JUDICIAL COURTHOUSE**

---

---

**PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:**

1. **Additions:** On sheet TO, Electrical Specifications section F.2 shall state that all occupancy sensors installed in common area such as corridors, large areas, stairwells, etc. shall be interconnected with low voltage wiring as recommended by the manufacturer to operate as one unit.

2. **Clarifications:** Systems that are specified on the plans in the basement holding cell area have been approved by the Sheriff's Department.

---

---

**THE BID DUE DATE AND TIME REMAINS 2 PM, WEDNESDAY, 1 SEPTEMBER 2010.**

---

---

**THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.**

8-26-10  
DATE

William R. Parson  
WILLIAM PARSON, CPPO  
PURCHASING AGENT