

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO 11-8-8-4

FOR: CRESTHILL DRAINAGE IMPROVEMENTS - PHASE I

---

---

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

NOTE:

Replace current Bid Sheets with the attached *REVISED* BID SHEETS (2 sheets).

Note: Questions received:

1. Q: The wing wall (12") and culvert (10") appear to have different thicknesses. Is this correct?  
A: *Both thicknesses are correct. The details on sheet 17 of the plans are to be used for the culvert only and not the wing wall. The culvert wing wall are to be constructed in accordance with details on plan sheet 14.*
2. Q: The "Vbituminous Pavement Replacement" detail on sheet 14 of 23 addresses the pipe on Laberta that crosses the street transversely. Is there a detail for the pipe longitudinal to Laberta, and also the patch over the culvert at Whitefield?  
A: *The cut and patch detail is to be used for all pavement areas that are shown to be cut and patched.*

---

---


**BIDS REMAIN DUE: 2PM, TUESDAY, MARCH 29, 2011.**

---

---

THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

3-21-11  
DATE

  
ROBERT E. MARSHALL  
SENIOR PROCUREMENT SPECIALIST  
CHATHAM COUNTY

**BID SCHEDULE**  
**PROJECT: CRESTHILL PHASE 1 DRAINAGE IMPROVEMENTS**  
**Revised 3-16-11**

Item	Description	Unit	Quantity	Unit Price	Item Total
<b>General</b>					
1.	General Conditions / Mobilization (shall not exceed 10% of the total bid amount)	LS	1		
<b>Earthwork</b>					
2a.	Laberta Blvd. Clearing: Includes removal of piping, headwalls, driveways, etc.	LS	1		
2b.	Whitfield Avenue Clearing: Includes removal of piping, headwalls, driveways, etc.	LS	1		
3a.	Grading, General Laberta Blvd.	LS	1		
3b.	Grading, General Whitfield Avenue	LS	1		
4a.	Remove and Replace Unsuitable Material Laberta Blvd.	CY	105		
4b.	Remove and Replace Unsuitable Material Whitfield Avenue	CY	155		
<b>Roadway</b>					
5a.	Cut and Patch Pavement Laberta Blvd.	SY	350		
5b.	Cut and Patch Pavement Whitfield Avenue	SY	110		
6.	Concrete Swale with Fillets	EA	1		
7.	18" Roll curb and Gutter	LF	440		
8.	Remove and Replace Concrete Driveways	SY	120		
9.	Remove and Replace Concrete Walkways	SY	30		
10.	Remove and Replace Sidewalk at Whitfield Avenue	SY	20		
<b>Drainage</b>					
11.	8'x6' Box Culvert w\Stone Bedding	LF	55		
12.	Box Culvert Headwalls	EA	2		
13.	Box Culvert Water Diversion\Dewatering	LS	1		
14.	24" RCP w\Stone Bedding	LF	304		
15.	18" RCP w\Stone Bedding	LF	48		
16.	Grate Inlet Over Box Culvert	EA	1		
17.	Type "C" Curb Inlet	EA	1		
18.	Type "B" Curb Inlet	EA	4		
19.	Double Grate Inlet	EA	1		
20.	Single Grate Inlet	EA	2		
21.	Connect To Existing Manhole Sta. 0+69.13	LS	1		

**PROJECT: CRESTHILL PHASE 1 DRAINAGE IMPROVEMENTS Revised 3-16-11**

<b>Erosion Control</b>					
22a.	Construction Exit Laberta Blvd.	EA	2		
22b.	Construction Exit Whitfield Avenue	EA	1		
23.	Type "A" Silt Fence	LF	500		
24.	Type "C" Silt Fence	LF	320		
25.	Rip Rap: Type 1	SY	375		
26a.	Grassing Laberta Blvd.	SY	850		
26b.	Grassing Whitfield Avenue	SY	580		
27a.	Sodding Laberta Blvd.	SY	850		
27b.	Sodding Whitfield Avenue	SY	360		
28a.	Sediment Traps Laberta Blvd.	EA	8		
28b.	Sediment Traps Whitfield Avenue	EA	1		
29a.	Tree Protection Fence Laberta Blvd.	LF	400		
29b.	Tree Protection Fence Whitfield Avenue	LF	350		
30.	Remove and Replace Shrubs	EA	12		
<b>Traffic</b>					
31a.	Traffic Control Laberta Blvd.	LS	1		
31b.	Traffic Control Whitfield Avenue	LS	1		
32.	Remove and Replace Mailboxes and Signs	LS	1		
33.	Type "W" Guardrail with Anchorages	LF	125		
<b>Water and Sewer System</b>					
34.	1" Service Connections with Meters	EA	5		
35.	Relocate 14" waterline without service interruption as shown on plans. Price includes all items necessary to perform the work shown.	LS	1		
36.	24" Steel Casing for waterline	LF	25		
37.	Relocate 8" force main without service interruption as shown on plans. Price includes all items necessary to perform the work shown.	LS	1		
38.	16" Steel Casing for force main	LF	25		
<b>Add Alternate 1: Overlay Laberta Blvd.</b>					
39.	1" Pavement Overlay on Laberta Blvd.	SY	1600		

**Total Base Bid** \_\_\_\_\_

(items 1-38)

**Total Add Alternate 1:** \_\_\_\_\_

**Total Bid** \_\_\_\_\_

NAME / TITLE \_\_\_\_\_

COMPANY \_\_\_\_\_

ADDRESS \_\_\_\_\_

PHONE / FAX NO'S. \_\_\_\_\_