

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 2 TO 10-7-11-7

FOR: Installation of Thermoplastic Polyolefin (TPO) Roofing Membrane at the Savannah-Chatham CNT Administrative Building

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

CLARIFICATIONS:

1. **Scope of Work, Section F. Flashing and Trim, 5. Curb cap flashing - Should read: "Perimeter cap flashing type and color to match existing.**
2. **Scope of Work, Section A. Contractors responsibilities will include, 2. Should read: "Removal and disposal of top layer of all old existing aggregate material from roof surface. Make sure the roofing area is completely smooth, repair holes and cracks with a non-shrink roofing material."**

ADDITIONS:

1. **Scope of Work, Section A. Contractors responsibilities will include, 4. "Contractor will be responsible for installing the recommended ½ inch x 4 inch x 8 inch TOP manufacture approved retro-fit board. Apply directly to old substrate to provide a smooth and continuous membrane support.**
2. **Scope of Work, Section A. Contractors responsibilities will include, 5. "Safety walkway pads are to be located at all access points (hatches, hvac units, etc.)"**
3. **Scope of Work, Section C. Special Conditions, 5. Contractor and his/her employees shall be subject to a background check prior to working on site.**
4. **Scope of Work, Section A. Contractors responsibilities will include, 6. Contractor will be responsible for providing a dumpster for all construction debris. 7. Since access to the building is limited Contractor must provide portable toilets on the construction site.**

CHANGES:


1. **Specifications, "An additional approximate 2,470 square feet of surface is added to the project. This addition is the front entry connecting roof connecting the canopy to the building."**

2. Scope of Work, Section E. Quality Assurance, 3, Should read:” Contractor will be responsible for scheduling of manufacture’s technical representative inspection(s), prior to completion of project, to insure warranty will be issued. Owner must be present at time of inspection.

THE QUOTE DUE DATE AND TIME REMAINS 2 PM, TUESDAY, 9 MARCH 2010.

THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

3-2-10
DATE



WILLIAM PARSON
PURCHASING AGENT
CHATHAM COUNTY