

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 2 TO 11-8-8-4

**FOR: CRESTHILL DRAINAGE IMPROVEMENTS - PHASE I**

---

---

**PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:**

**Response to question received:**

Q: Is the installation of a pre-cast culvert acceptable at the Whitefield Avenue location, or is it required to be cast-in-place ?

A: Pre-cast is acceptable at the Whitefield Avenue location. If using pre-cast, GDOT standard 2530P and 2535P shall be used for the barrels and the ends.

---

---


**BIDS REMAIN DUE: 2PM, TUESDAY, MARCH 29, 2011.**

---

---

**THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.**

3-25-11  
DATE



---

ROBERT E. MARSHALL  
SENIOR PROCUREMENT SPECIALIST  
CHATHAM COUNTY