

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO BID NO. 11-1-16-5

FOR: SALLIE MOOD SOCCER COMPLEX IRRIGATION IMPROVEMENTS

=====


PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. Section 11063: The irrigation pump shall deliver 480 gpm at 112 psi.
2. Electrical power access: Limits of electrical work is shown on Drawing E1. Southern Company will bring service to the site and set the transformer.

THE BID OPENING REMAINS: 2:00 PM, THURSDAY, SEPTEMBER 2, 2010

THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

08/31/10
DATE


WILLIAM R. PARSON, CPPO, PURCHASING AGENT
CHATHAM COUNTY, GEORGIA