

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 2 TO BID NO. 11-1-16-5

FOR: SALLIE MOOD SOCCER COMPLEX IRRIGATION IMPROVEMENTS

=====

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:


1. County will accept DR25 (Class 150) effluent pipe.
2. Suction piping is ductile iron transitioning to HDPE as shown on the drawings.

NO MORE QUESTIONS WILL BE ADDRESSED

THE BID OPENING REMAINS: 2:00 PM, THURSDAY, SEPTEMBER 2, 2010

THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

08/31/10
DATE



WILLIAM R. PARSON, CPPO, PURCHASING AGENT
CHATHAM COUNTY, GEORGIA