

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO 10-4-1-7

FOR: Construction of New Pump House on Paxton Drive


PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. **Question: Paint cement board ceiling same as wood? Interior and exterior of CMU?**
Answer: Paint the ceiling cement board same as wood. Paint both interior and exterior CMU walls. Paint color is practical beige (Sherwin Williams 6100).
2. **Question: Who will determine if equipment is considered obsolete?**
Answer: The County determine if the equipment is obsolete.
3. **Question: Please confirm all plumbing is to remain as is.**
Answer: All plumbing is to remain the same. The County will remove all caustic materials from work site.
4. **Question: Please clarify 2 x 6 vs. 2 x 8 for rafters.**
Answer: 2 x 6 rafters are to be used as the roof rafters and 2 x 8 rafters are to be used as the hip rafters.

THE BID DUE DATE AND TIME REMAINS 2 PM, TUESDAY 10 NOVEMBER 2009.

THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

11-6-09
DATE



WILLIAM PARSON
PURCHASING AGENT
CHATHAM COUNTY