

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO Bid No. 10-4-2-7

FOR: Photovoltaic Power system & Solar Water Heater at the Resource Conservation Education Center

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

Clarifications

1. Required licenses will be a Georgia Utility License at minimum.
2. Section 4.2, Solar Water Heating System - Last sentence is CORRECT. (This system must be ungradable to provide heat for the building in the winter time and purchased from a company that is a trade partner of the United States.
3. Section 4.1, A, Scope of Work - The goal of the system is 5KW. Some solar panel companies designs generate a fraction more or less power/watts than others; the range stated in the bid of 4.9 to 5.2KW is to not exclude those designs.
4. Section 3.4, Warranty Requirements - Should read a minimum 20 year warranty on power production.
5. Section 4.1, B, Mounting - The roof is designed for 125 mph winds, so the panel mounts must meet or exceed 125 mph. The structure was designed for solar panel installation. Mounting systems are to be used that do not require roof penetrations.
6. Section 4.1, C, Grid Inverter - The inverter shall be 5KW single phase and a grid connect only.
7. Section 4.2 Solar Water Heating System - There are no substitutions for what is stated in the Bid document for this system. An industry standard warranty is required.

Additions:

1. Section 4.1, B., Panels on container bay roof to meet a minimum of 20 - 32 degree angle. Basic installation drawing shall be submitted with bid.

THE BID OPENING DATE STILL REMAINS 2 PM, TUESDAY, 8 DECEMBER 2009.

**THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND
MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.**

12-03-09
DATE



WILLIAM PARSON
PURCHASING AGENT
CHATHAM COUNTY