

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO 15-0124-4

FOR: VIDALIA CANAL EXTENSION

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

NOTE: PLEASE SEE THE FOLLOWING RESPONSES TO QUESTIONS RECEIVED:

1. Q) Pay Line Item 17 mentions filter fabric and geo-grid. It appears the detail plans show only filter fabric. Can you clarify?
A) *The geo-grid listed in the bid schedule on item # 17 will be placed below the fabric on the Typical Stone Access Road Detail. The geo-grid shall be Tensar TX 140 or equivalent.*
2. Q) Please clarify the pipe bedding detail. Is it intended to have an additional 24" - 36" trench width on each side of the pipe? Or a total 24" - 36" additional trench width (12" - 18" each side of pipe) ?
A) *The trench should be wide enough to ensure compaction is reached under the haunches of the pipe. This typically is 24" on each side of pipes 30" or smaller and 36" on each side of pipes over 30".*
3. Q) Going over the bid sheet, I noticed for 6" Stone Base Road with Filter Fabric and Geo-grid, the quantity shows 650 SY. I believe that this is an error. Please advise.
A) *The stone base road will not be installed for the entire length of the access road. The stone road will only be installed where directed by the County.*

THE BID OPENING DATE REMAINS 2 PM, TUESDAY, DECEMBER 8, 2015.

THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

12-2-15
DATE


ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST