

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO BID# 20-0101-5

FOR: ANNUAL CONTRACT FOR POOL PAK UNITS PREVENTATIVE MAINTENANCE AND REPAIR SERVICES AT THE CHATHAM COUNTY AQUATIC CENTER

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:


1. **Question:** What are the belt and filter sizes of the system?
Answer: Filters – 20x25x2 Poly, 3 Ply, 4-linked on 25 side (15/40)+N (26-0009Z002) Quantity of 16 for each unit. Belts – Belt, V, BP55,56.8 Datum Length Single (28-0011Z015) Quantity of 4 for each unit. Belt, V, BP84,85.8 Datum Length Single (28-0011Z037) Quantity of 4 for each unit.
2. **Question:** Will the middle fan over the pool be included?
Answer: No.

**BID DUE DATE WILL REMAIN 2:00PM,
JANUARY 28, 2021**

BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

January 25, 2021

DATE


MARGARET H. JOYNER
PURCHASING DIRECTOR
CHATHAM COUNTY