

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO BID# 20-0100-5

**FOR: ANNUAL CONTRACT FOR VALENT AIR MANAGEMENT SYSTEM  
PREVENTATIVE MAINTENANCE AND REPAIR SERVICES AT THE CHATHAM  
COUNTY AQUATIC CENTER**

**PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR  
CHANGES:**

1. **Question:** What are the belt and filter sizes of the system?  
**Answer:** Filters for the Valent unit should be 1" aluminum on the hood and 2" merve 8 on supply. Below is from the manufacturer:


PART #	DESCRIPTION
450232	Outside air hood filters' Alum 16X20X1
465056	Supply air filters; 20X24X2

**BID DUE DATE WILL REMAIN 2:00PM,  
JANUARY 28, 2021**

**BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.**

January 21, 2021

DATE

  
MARGARET H. JOYNER  
PURCHASING DIRECTOR  
CHATHAM COUNTY